

AGENDA
CITY OF CENTRALIA, MISSOURI
Board of Aldermen
Public Works and Public Utilities Committee

Monday, July 1, 2013
7:00 p.m.
City Hall Council Chambers

- I. ROLL CALL
- II. PLEDGE OF ALLEGIANCE
- III. COMMENTS FROM CITIZENS
- IV. REMARKS BY CLIFFORD DE LA ROSA
- V. PUBLIC WORKS
 - A. Activity Report
 - B. Streets
 - C. Sanitation
 - D. Stormsewer
 - E. Other
- VI. WATER AND SEWER DEPARTMENT
 - A. Activity Report
 - B. Other
- VII. ELECTRIC DEPARTMENT
 - A. Activity Report
 - B. Other
- VIII. OTHER
- IX. AS MAY ARISE
- X. ADJOURN

STREET & SANITATION DEPARTMENT

Activity Report for June 2013

- 👉 Daily trash collection routes
- 👉 Weekly cardboard and bi-weekly curbside recycling routes
- 👉 Added rock and smoothed up several shoulders and ends of driveways
- 👉 Hauled all of the barricades from Anchor Festival back and stacked them back inside of the street barn
- 👉 Patched potholes
- 👉 Replaced both batteries in dump truck #4
- 👉 Did lots of locates this month
- 👉 Hauled 4 loads of fill dirt to lot at nw corner of Alco and Central where they tore down house
- 👉 Swept streets around town
- 👉 Loaded 2 trucks with mulch
- 👉 Hauled off 4 loads of plastic to Ryan Ent. in Millersburg
- 👉 Assembled and delivered 4 trash carts to city residents
- 👉 Hauled off 4 loads of recycling to Civic Recycling in Columbia
- 👉 Reset speed limit sign on west Lakeview that the wind blew over
- 👉 Dug out and set 12' of 10" metal culvert for driveway at 521 Central
- 👉 Replaced the battery in the backhoe
- 👉 Stained the cemetery directory
- 👉 Spent 2 days and finished painting walls where 105 Allen used to be
- 👉 Met and talked with several homeowners about culverts
- 👉 Tore out collapsed culvert and set 20' of 12" plastic pipe at 830 n. Hickman for the homeowner
- 👉 Reset culvert at 720 s. Rollins and added on 9' of 10" metal culvert for Cindy Barnes
- 👉 Mowed around town and at the old city landfill
- 👉 Relocated stop sign at Railroad and Allen to behind the guardrail
- 👉 Did some ditch cleaning on Orchard and on Kennan
- 👉 Trimmed tree limbs blocking signs
- 👉 Cleaned up street barn and lot
- 👉 Hauled off brush from drop off site to the landfill brush pit
- 👉 Bladed tear drop at the park, Ivy, Campbell, Columbia, and an alley
- 👉 Dug out and set 30' of 10" plastic pipe for driveway for new house on Pool
- 👉 Cut the ends off of a smashed culvert at Burnett and Allen
- 👉 Hauled and spread 4 loads of rock on s. Columbia and 2 loads of rock on Ivy Lane and bladed them both in preparation of dust control being done
- 👉 Spent about 9 days working on the Switzler street project:
 - Built forms for the inlets
 - Have set and poured 3 inlet boxes
 - Dug out and set 152' of 15" plastic pipe
 - Dug out and set 34' of 12" plastic pipe
 - Poured floors inside of the boxes

**ACTIVITY REPORT
WATER DEPARTMENT
JUNE 2013**

- Moved three fire hydrants back off Switzler for new street improvements
- Moved 5 water services and meter jars back to be clear of sidewalks on Switzler
- Added two water and sewer services on Switzler at 507 and 701 for future use
- Replaced leaking valve at Switzler / Lee street
- Met with Midland GIS and assisted where needed on mapping system
- Assisted Water District #10 in shutting off water on leak at Sunnydale
- Assisted Lot # 61 at Tidball's shut off water due to leak
- Moved rip-rap along discharge structure at N.E. Lagoon to stop erosion
- Hauled clay to low spot on primary basin to build up
- Called out to 614 Rodemeyer to assist in fixing leak
- Assisted Insituform with sewer lining questions
- Mowed at overland flow fields and sprayed
- Worked with Chance boring crew to avoid conflicts with utilities
- Followed up on sewer issue at 404 Bradford to make sure it was properly fixed
- Dirt work at several locations from previous dig sites
- Assisted electric department with installing relay at N.E. Pump house to stop surges
- Replaced manhole frame and lid at Rt. CC
- Took out old ¾" service and changed to 1" at Pratt / E. Switzler – Brooks
- Called in to shut off water at 620 Booth
- Called in to shut off water at 326 Alco
- Called in to reconnect water at Lot 13 Tidball's
- Ran sewer camera in sewer main on Pool for Romine to find old Meador service tap
- Straightened meter setter at Country Club to ease in shutting off service
- Called to MFA to shut off water due to leak
- Called to check leak at 801 Hulen – residents
- Changed key valve leaking at 911 S. Rollins
- Used vac trailer to locate water main in electric department path
- 9 meters read for office use
- 18 disconnects for nonpayment

ELECTRIC DEPT.
JUNE 2013 ACTIVITY REPORT

1. Hauled brush/yard waste as necessary
2. Hauled/chipped brush around town during Anchor Fest week
3. Repaired streetlights – repaired burnt wire in pole 46 along Hwy 124 overpass, 627 S Central, Sims/Maple, Lakeview/Ash
4. Repaired security lights – 422 N. Lee
5. Trimmed trees - 1 Leabrook, 634 N. Hickman, Centralia Fairgrounds, 627 N. Jefferson, Howard Burton/Switzler
6. Removed trees – 460 Pratt, 304 Stone, 820 S Rollins
7. 11 Leabrook – repaired bad connection @ pole
8. Removed temp electric boxes from City Square after Anchor Fest
9. Midland GIS – Recorded locations of poles and pad mounted electrical equipment
10. Asplundh – Trimmed five easements and ground up 19 stumps
11. 607 Clayton – disconnected/reconnected service for roofer
12. NE Lagoon – added phase failure relay to overland flow pump control panel
13. 205 S Adams – strung wire and connected new overhead service
14. Pole 6090 – finished pole transfer, hung transformer and connected service drops
15. Pole 6091 – finished pole transfer, connected service drops, removed old transformer
16. 421 W. Southgate – disconnected meter loop for customer to disconnect second shed from meter base
17. Miles/Leabrook easement – tilled dirt, planted grass seed
18. Southwest Circle easement – removed old poles, tilled dirt, planted grass seed
19. 509 S Adams – pulled wire, connected new underground service
20. 923 Mystic Drive – pulled wire, connected new underground service
21. Outage on 6/15 – limb on main circuit along Rodney Griffin – removed limb, reset breaker
22. 628 N. Hickman – limb fell on service drop & broke service mast, customer had mast repaired, restored service
23. CHS/Rollins project – started trenching & installing conduit
24. 901 Hampton – pulled wire, connected new underground service
25. 941 Windset – connected temp service for construction
26. Sunset St – trimmed limbs for street clearance
27. Cemetery – trimmed limbs for flag clearance
28. Outage on 6/22 – limb on main circuit in alley between Sappington/Mayes Meadows – removed limb
29. Forrest Chevrolet – connected permanent service at new location
30. 6 Leabrook – trenched, laid conduit, pulled wire to repair underground service