

AGENDA
CITY OF CENTRALIA, MISSOURI
Board of Aldermen
Public Works and Public Utilities Committee
Monday, November 2, 2015
7:00 P. M.
City Hall Council Chambers

- I. ATTENDANCE
- II. PLEDGE OF ALLEGIANCE
- III. COMMENTS FROM CITIZENS
- IV. PUBLIC WORKS
 - A. Activity Report
 - B. Streets
 - 1. Jefferson Street Sidewalk Project Update
 - C. Sanitation
 - D. Storm sewer
 - E. Other
- V. WATER AND SEWER DEPARTMENT
 - A. Activity Report
 - B. Water
 - C. Sewer
 - D. Other
- VI. ELECTRIC DEPARTMENT
 - A. Activity Report
 - B. Update on Underground Conduit Installation (Boring) Project
 - C. Other
- VII. OTHER
- VIII. AS MAY ARISE
- IX. ADJOURN

***STREET and SANITATION DEPARMENT
Monthly Activity Report for October 2015***

1. Daily trash collection
2. Weekly cardboard and bi-weekly curbside recycling
3. Finished mowing street ditches around town
4. Finished up weed eating around town
5. Took out loaner dumpsters several times this month
6. Added rock and smoothed up several alleys and shoulders
7. Spent 4 days digging out and hauling clay to repair several spots on the old landfills
8. Hauled off 3 loads of plastic to City of Columbia recycling facility
9. Hauled off 3 loads of plastic to Ryan Ent. in Millersburg
10. Hauled off 3 loads of recycling to City of Columbia recycling facility
11. Mowed out at the landfill area
12. Assembled and delivered 6 trash carts to city residents
13. Did 66 locates this month
14. Hauled 2 loads of mulch to the city park per Bennett
15. Did some ditch cleaning on Howard Burton, Fullenwider, & Stone
16. Unloaded 2 pallets of ice melt and put into shed
17. Dug out and hauled off 2 stumps at the city park per Bennett
18. Hauled lots of barricades and 2 dumpsters to the city square for the BBQ contest and then hauled everything back to the shop afterwards
19. Saw cut asphalt in 6 places beside the Rec Center per Bennett
20. Assisted the Police Dept. in blocking streets for the Homecoming Parade
21. Dug out and set 40ft of 12in plastic pipe for driveway at new house on Ivy Lane
22. Dug out and poured concrete to patch street cuts: 1 on Rodney Griffin, 1 at Bruton/Allen, 1 on Parkview, 1 on Southland, 1 on Bryson, 1 on Adams, 1 on Bruton
23. Spent a few days hauling off brush and leaves from drop off site to the landfill
24. Dug out and replaced 40ft of 15in metal culvert on Switzler st. that had rusted out
25. Moved dirt at Bicentennial Park from pile to ball field per Bennett
26. Dug out and cut off damaged culvert and added 20ft of 10in metal culvert in alley behind 818 e. Booth for homeowner
27. Spent 1 day hauling fill dirt from debris pile at the landfill out to Hickman/Fairgrounds for new church
28. Cleaned and did maintenance on equipment: #91 work truck, #90 backhoe, #76 dump truck, #77 dump truck, #25 pickup
29. Spent 3 days hauling cinders from City of Columbia to stock pile at landfill for winter
30. Went and got load of cold mix and patched potholes around town
31. Talked with several homeowners about driveway culverts and storm sewers

**ACTIVITY REPORT
WATER DEPARTMENT
OCTOBER 2015**

- Fixed broken 6" water main at Gano Chance / S. Rollins
- Repaired leak on meter setter at 706 N. Allen
- Repaired leak on Gano Chance / Jefferson – 6"
- Made new water tap at MFA for new building
- Replaced 6" meter at #3 Well
- Flushed sewer main between Clayton / Porter to open blockage (roots)
- Flushed sewer main at Mayes Meadow to open blockage
- Flushed sewer mains for cleaning purposes at Miles, Switzler, S. Rollins, and N. Columbia
- Hauled 220 loads of lime to Stanton fields – 2
- Changed leaking key valve 704 N. Allen
- Changed leaking key valve at 721 S. Allen
- Shut off water at 1017 E. Booth due to leak on their side
- Shut off water at 324 Country Club Drive due to leak on their side
- Worked on blowdown motors at Plant
- Repaired leak at Lot 38 Tidball's on service
- Found leak at 303 S. Barr and reported to resident
- Verified leak at 614 Ivy with resident
- Put meter backflow device back together and installed meter for new Barber shop on S. Allen / Sneed
- Cleaned well houses, pump houses and towers and winterized
- Completed dirt work and seeded at #5 Mayes Meadow
- Set up and take down meter setters for Bar-B-Que Contest
- Call in to do emergency locate at 1021 Fairview
- Pulled pumps at Fountain Road twice to clear obstructions
- Meeting on energy savings with engineer
- Met with New Beginnings Church on sewer issues and located
- Met with 413 S. Rollins to avoid utility conflicts during fence construction
- Met with Gonzales Engineering on Plant aerator
- Reset lime sled cable and moved sled
- Call in to check leak at 803 Southland –residents
- Met with 721 S. Allen about leak on their side
- Replaced sump pump at Methodist Church
- Repaired dirt berms at overland flow fields with clay
- Reported leak at 529 S. Allen
- Call in at 562 Tidball to check leak – resident leak
- Call out to 607 Sappington to assist in shutting off water
- Inspected sewer cap at old Champion Academy house for school
- Changed oil in #6, #3 and #19

- Inspected sewer tap at 909 Southland
- Assisted plumber locate sewer service at 485 Pratt
- Repaired sewer main at 802 S. Rollins after tap was broken off replacing service
- 17 disconnects for nonpayment
- Read all utility meters for billing purposes

ELECTRIC DEPT.
OCTOBER 2015 ACTIVITY REPORT

1. Daily readings – 56
2. Daily locates – 64
3. Re-reads – 15
4. Disconnects – 18
5. Assisted Sanitation Department with repairing ground cover at old landfill site
6. 418 N Fullenwider – trimmed limbs away from service drop
7. E Sims St – removed old poles, filled holes
8. Loaded 2 poles and delivered to Sims/Walnut
9. Hwy 22 – repaired 12 street lights
10. Repaired street lights – Ann/Fairway, Heidi/Ryan
11. Mark & Jeff attended MPUA line-worker meeting
12. 566 W Tidball – trimmed trees for line clearance
13. 429 S Walnut – trimmed trees for line clearance
14. Trimmed trees in alley between Hickman/Allen from Switzler to Hwy 22
15. Loaded and delivered two poles to 808 & 814 S Allen
16. SD Myers took oil samples @ substations
17. 808 S Allen – set new pole in rear easement, framed & transferred three-phase primary lines, hung transformer, transferred secondary mains and 4 services to new pole, transferred phone and CATV, pulled old pole, filled hole
18. 721 E Early – pulled wire and connected new service, disconnected temp service
19. 814 S Allen – framed pole with cross arm and pole top pen, set new pole in rear easement, transferred pole, moved transformer, primary lines, secondary lines, and service drops, also transferred phone and CATV
20. Cobblestone Lake Estates –terminated primary cable, energized new circuits
21. Set up electric boxes for BBQ fest
22. Disconnected/reconnected service drop for customer @ 431 S Rollins to allow for painting around weather head
23. Met w/ 360 Energy to look at various City buildings to identify possible upgrades for energy efficiency
24. Repaired street light – Jefferson/Sneed
25. Trained with new locator
26. Removed “Welcome” sign along Hwy 124
27. Removed duplex wire on ground at teardrop at East City Park, wire no longer needed for Water Plant communication with Well 3
28. Assisted @ Fountain Road lift station with pump cleanout, twice
29. 201 S Allen – trimmed tree away from lift pole and wires
30. 712 S Allen – trimmed trees for line clearance
31. Removed brush @ tear drop area of East City Park for directional boring project
32. Sims irrigation – Checked pivot, bad connection @ collector ring, cleaned connection, works for now, ordered and received two collector rings, Sims will install
33. Mowed easement at tear drop at East City Park

34. Mowed at shop and WSS
35. Set new pole and transferred lines along E Sims St east of Walnut, pulled pole, filled old hole
36. Moved lines on corner pole at Sims/Walnut to allow new pole to be set
37. 111 S Howard Burton – connected temp service
38. Sims/Walnut pole – set anchor and pole, transferred lines, installed cutouts & made connections
39. 612 Early St – pulled wire and connected new service on garage
40. 202 N Jefferson MFA – Set riser pole for new service, Installed 4” conduit from new riser pole to transformer pad, installed aluminum equipment mount, pulled 250’ x 3-phase #2 primary, set 75kVA transformer, terminated elbows, installed elbow arresters, installed secondary lugs, made all connections @ transformer, installed cutouts, riser arresters, terminated riser wires @ pole, tested primary underground wire, installed metering, energized new service
41. Picked up Bobcat in Columbia, repair completed
42. 850 Tidball – removed old pole, all lines had been transferred to new pole
43. 909 Southland – repaired underground secondary wire damaged by plumber excavating for new sewer
44. Mark attended power purchasing presentation in Hannibal with Matt
45. 617 E Head – removed tree
46. Changed oil in truck 38
47. 509 Tarr St – removed two trees
48. Installed temp meter @ Well 6 so existing meter can be repaired
49. Apprentice test – Clayton & Andrew
50. Mark attended Power Quality Unit on harmonics in Columbia
51. 451 Bradford – removed tree trunk in backyard by alley
52. Jenkins St – removed tree trunk along street
53. Installed conduit in floor @ Well 3 for power to new flow meter